

Town of Bar Nunn-WY5600067 2025 Consumer Confidence Report

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water comes from Central Wyoming Regional Water System. They treat and deliver our water to the Bar Nunn system. The Quality report is available at:
https://www.wyowater.com/documents/822/2025_RWS_CCR_Report_only.pdf

Source water assessment and its availability

Our source water assessment is available at <https://www.wyowater.com/>

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some

Town of Bar Nunn-WY5600067 2025 Consumer Confidence Report

cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Attend a meeting of the Regional Water board. <https://www.wyowater.com/>

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food

Town of Bar Nunn-WY5600067 2025 Consumer Confidence Report

coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.

- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Town of Bar Nunn-WY5600067 2025 Consumer Confidence Report

Other Information

If you want additional information about how our water is treated and delivered to Bar Nunn from Central Wyoming Regional Water System, check out the website:

<https://www.wyowater.com>

Additional Information for Lead

The system inventory includes lead service lines.

The Bar Nunn system does not have any confirmed lead pipes or connections in the system. There are a small number of service lines that are of unknown material. They EPA requires us to classify the unknown lines as "potential lead" until we verify what material they are made of. The verification process is labor intensive and is ongoing. You can request a copy of the inventory from the water system office.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Bar Nunn is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the Town of Bar Nunn (Public Watersystem Id: WY5600067) by calling 307-237-7269 or emailing dustin@barnunnwy.gov. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at

<http://www.epa.gov/safewater/lead>

Town of Bar Nunn-WY5600067 2025 Consumer Confidence Report

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	2.1	0.21	2.1	2025	No	Water additive used to control microbes
Microbiological Contaminants								
Total Coliform (RTCR) (% positive samples/month)	NA	TT	NA	NA	NA	2025	No	Naturally present in the environment
Violations and Exceedances								

Town of Bar Nunn-WY5600067 2025 Consumer Confidence Report

Additional Monitoring

As part of an on-going evaluation program the EPA has required us to monitor some additional contaminants/chemicals. Information collected through the monitoring of these contaminants/chemicals will help to ensure that future decisions on drinking water standards are based on sound science.

Under the Fifth Unregulated Contaminant Monitoring Rule (UCMR5), EPA is gathering information on the occurrence of 29 per- and polyfluoroalkyl substances (PFAS) and lithium in drinking water. UCMR5 is intended to improve understanding about the presence and quantity of these substances in public drinking water systems, and EPA often does not have full knowledge of the health effects for these unregulated contaminants. The UCMR5 data collected on PFAS and lithium from drinking water systems will help the EPA make determinations about future regulations and other actions to protect public health under the Safe Drinking Water Act. The process of developing regulatory standards is careful, deliberative, and data based. Monitoring for contaminants that are not regulated also helps federal, state, and other researchers prioritize studies for health effects information, identify data gaps, and determine the need for future studies to improve our understanding of the possible health risks associated with these contaminants in public drinking water. Information collected through the monitoring of these contaminants will help to ensure that future decisions on drinking water standards are based on sound science. For more information about UCMR5, visit <https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule>.

The Town of Bar Nunn conducted 3 separate test samples for UCMR5 and lithium was detected in those samples. The details of each sample are:

Date	Result
6/16/2025	26 ug/L =.026 mg/L
9/23/2025	35 ug/L =.035 mg/L
12/16/2025	52 ug/L =.052 mg/L

Name	Average Reported Level	Range	
		Low	High
lithium (mg/L)	0.0376	0.026	0.052

Town of Bar Nunn-WY5600067 2025 Consumer Confidence Report

Lithium is a naturally occurring metal and may be found at higher concentrations in certain parts of the country, particularly in groundwater sources in arid locations in the Western U.S.

Lithium has been used in pharmaceuticals for a long time to treat certain medical conditions under the care of a physician. Despite the abundance of information on patients receiving lithium at therapeutic levels, there has historically been limited information available to evaluate health risks in people at the levels associated with typical drinking water consumption, which are thought to be much lower than patients prescribed lithium as a therapy. Getting a better understanding of how much environmental lithium the public may be exposed to is one of the reasons the EPA is choosing to monitor for the presence and levels of lithium in drinking water systems around the country.

At present, EPA cannot confidently estimate the risk for people with lithium exposures from drinking water between the UCMR5 reporting limit of 9 µg/L (micrograms per liter) and a much higher concentration equivalent to a therapeutic dose. Therapeutic doses of lithium generally range from 600 to 1,200 mg/day (milligrams per day), which would be the equivalent of drinking water containing ≥ 240,000 µg/L lithium. The science on the potential for lithium’s effects on human health, and at what levels including those which may be present in the environment, is still evolving.

For more information on lithium, visit <https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule#lithium>

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
mg/L	mg/L: Number of milligrams of substance in one liter of water
% positive samples/month	% positive samples/month: Percent of samples taken monthly that were positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Town of Bar Nunn-WY5600067 2025 Consumer Confidence Report

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level
90th Percentile	Compliance with the lead and copper action levels is based on the 90th percentile lead and copper levels. This means that the concentration of lead and copper must be less than or equal to the action level in at least 90% of the samples collected.

For more information please contact:

Contact Name: SMART, DUSTIN
 Address: 1500 Palomino
 BAR NUNN, WY 82601
 Phone: 307-237-7269